

IGEM/GM/PRS/29 Communication 1790

Medium pressure two-stage meter regulators for gas flow rates not exceeding 6 m³ h⁻¹



Founded 1863 Royal Charter 1929 Patron: Her Majesty the Queen





IGEM/GM/PRS/29 Communication 1790

Medium pressure two-stage meter regulators for gas flow rates not exceeding 6 m³ h⁻¹





Copyright $\ensuremath{\mathbb{C}}$ 2016, IGEM. All rights reserved Registered charity number 214001

All content in this publication is, unless stated otherwise, the property of IGEM. Copyright laws protect this publication. Reproduction or retransmission in whole or in part, in any manner, without the prior written consent of the copyright holder, is a violation of copyright law.

ISBN 978 1 905903 66 5 ISSN 0367 7850 Published by the Institution of Gas Engineers and Managers

For information on other IGEM Standards, visit our website, <u>www.igem.org.uk</u>.

IGEM/GM/PRS/29

CONTENTS

SECTION

1	Introduction	1
2	Scope	2
3	Legal and allied considerations	3
4	Materials	4
	4.1 General requirements	4
	• 4.2 Casing components	4
	4.3 Resistance to corrosion	4
	4.4 Polymeric components	4
5	Finish	6
6	Torsion and bending	7
	• 6.1 General	7
	• 6.2 Torsion	7
	• 6.3 Bending moment	7
7	Design and dimensions	8
	• 7.1 General requirements	8
	• 7.2 Non-adjustable regulators	8
	• 7.3 Adjustable regulators	8
	• 7.4 Connections	9
	• 7.5 Overpressure protection	9
	• 7.6 Vents and breathers	9
	• 7.7 Fault/failure mode effect analysis	10
8	Performance	11
	• 8.1 Test conditions	11
	 8.2 Strength and gas tightness 	11
	• 8.3 Outlet pressure	11
	• 8.4 Lock-up	12
	8.5 Speed of response	13
	8.6 Mechanical life	13
	• 8.7 Type test approval	13
9	Regulator setting and sealing	14
10	Protective device setting	15
11	Marking and labelling	16
12	Protection and packaging	18

APPENDIX

1	Glossary, acronyms, abbreviations, units and symbols	19
2	References	21
3	Type test on protective coatings	23
4	Torsion and bending moment tests	24
5	Size envelopes for regulator installations	26
6	Requirements for overpressure protection system	28
7	Type tests on regulators	32
8	Mechanical life test	36
9	Summary of type approval tests	37

FIGURES

1	Illustration of applied force and torque for mechanical strength tests	24
2	Surface mounted meter box	26
3	Semi-concealed meter box with E6 bracket	26
4	Semi-concealed meter box with top view index diaphragm meter	27
5	Semi-concealed meter box with ETM extension and ETM or U6 meter	27
6	Performance characteristics test apparatus	33
7	Lock-up and speed of response test rig	34

TABLES

1	Standard network tiers and corresponding pressures	2
2	Performance criteria for outlet pressure tests	12
3	Performance criteria for lock-up tests	12
4	Performance criteria for speed of response tests	13
5	Performance before accelerated mechanical life test	37
6	Performance after accelerated mechanical life test	38
7	Requirements for overpressure protection system	39

SECTION 1 : INTRODUCTION

- 1.1 This Specification is part of a series of Institution of Gas Engineers and Managers (IGEM) publications, providing a specification for selecting medium pressure meter regulators.
- 1.2 British Gas and latterly, National Grid Metering (NGM) developed a series of Specifications for key metering components based on its own suite of product requirements. These documents were made available to meter installers and purchasers under the title of Product Requirement Specification (PRS) 'e' documents. Originally these Specifications were made available through Advantica, as they were known at the time.

NGM has transferred the ownership of these documents to IGEM to make them available to the wider industry. It is some years since the original 'e' documents were updated and these have been withdrawn.

- 1.3 This Specification has been drafted by an IGEM Working Group, appointed and subsequently approved by IGEM's Gas Measurement Committee, and has been approved by IGEM's Technical Coordinating Committee on behalf of the Council of IGEM.
- 1.4 Manufacturers supplying two stage regulators for gas flow rates not exceeding 6 m³ h⁻¹ and inlet pressures exceeding 75 mbar but not exceeding 2 bar are to conform to the requirements of this Specification and to any other relevant documents to which reference is made herein.
- 1.5 Details on the installation of domestic-sized gas meters and associated components are given in BS 6400-2.
- 1.6 Terms such as "maximum operating pressure" (MOP), "maximum incidental pressure" (MIP) and "operating pressure" (OP) are used to reflect gas pressure terminology used in European standards. These terms will arise in all relevant IGEM Standards and, possibly, in other standards. Other terms have been introduced to assist in recognition of design information to be transferred between interested parties.
- 1.7 This Specification makes use of the term "must", "shall" and "should" when prescribing particular requirements.
 - the term "must" identifies a requirement by law in Great Britain (GB) at the time of publication
 - the term "shall" prescribes a requirement which, it is intended, will be complied with in full and without deviation
 - the term "should" prescribes a requirement which, it is intended, will be complied with unless, after prior consideration, deviation is considered to be acceptable.

Such a term may have different meanings when used in legislation, or Health and Safety Executive (HSE) Approved Codes of Practice (ACoPs) or guidance, and reference needs to be made to such statutory legislation or official guidance for information on legal obligations.

- 1.8 New and improved products, materials or production methods may be adopted prior to this Specification being updated. Amendments to this Specification will be issued when necessary and their publication will be announced in the Journal of IGEM and elsewhere as appropriate.
- 1.9 Requests for interpretation of this Specification in relation to matters within its scope, but not precisely covered by the current text, should be addressed to Technical Services, IGEM, IGEM House, High Street, Kegworth, Derbyshire, DE74 2DA. Such requests will be submitted to the relevant Committee. Any advice given by or on behalf of IGEM does not imply acceptance of any liability, and does not relieve any party of their obligations.
- 1.10 This Specification was published in September 2016.

SECTION 2 : SCOPE

- 2.1 This Specification defines the requirements for two-stage medium pressure (MP) meter regulators for use with 2^{nd} family gas (see BS EN 437) at flow rates not exceeding 6 m³ h⁻¹. Each regulator will have to be suitable for use on a pressure tier, or range of tiers, as defined in Table 1.
 - *Note 1:* Requirements for low pressure (LP) meter regulators for gas flow rates not exceeding 6 m³ h⁻¹ are given in IGEM/GM/PRS/3.
 - *Note 2:* Requirements for single-stage MP meter regulators for gas flow rates not exceeding 6 m³ h⁻¹ are given in IGEM/GM/PRS/28.

PRESSURE TIER	OPERATIONAL PRESSURES AT OUTLET OF EMERGENCY CONTROL VALVE (ECV)			DESIGN PRESSURES AT OUTLET OF ECV	
	DESIGN MINIMUM PRESSURE UPSTREAM (DmP _u) mbar	LOWEST OPERATING PRESSURE UPSTREAM (LOP _u) mbar	MAXIMUM OPERATING PRESSURE (MOP _u) mbar	DESIGN PRESSURE UPSTREAM (DP _u) bar	DESIGN MAXIMUM INCIDENTAL PRESSURE UPSTREAM (DMIP _u) bar
Medium ^{35*}	35	35	185 mbar	2.0	2.7
Medium ^{65*}	65	75	250 mbar	2.0	2.7
Medium ^{105*}	105	105	1.1 bar	2.0	2.7
Medium ^{180*}	180	180	1.6 bar	2.0	2.7
Medium ^{270*}	270	280	2.0 bar	2.0	2.7

* This number refers to the DmP of the upstream network.

TABLE 1 – STANDARD NETWORK TIERS AND CORRESPONDING PRESSURES

- 2.2 Regulators to this specification incorporate a two-stage pressure regulating device with integral relief valve that meets the requirements of Appendix 6 (hereinafter called regulators). They have a nominal outlet pressure of 22 mbar.
- 2.3 This Specification sets out the requirements for product type and production testing.
- 2.4 This Specification requires consideration of the life cycle of the product and its potential effect on the environment.
- 2.5 All pressures quoted in this Specification are gauge pressures unless otherwise stated.
- 2.6 Italicised text is informative and does not represent formal requirements.
- 2.7 Appendices are informative and do not represent formal requirements unless specifically referenced in the main sections via the prescriptive terms "must", "shall" or "should".