

INSTITUTION OF GAS ENGINEERS AND MANAGERS

GENERAL GAS PROCEDURES

AMENDMENTS. APRIL 2015

These Amendments apply to the following publications:

- **IGEM/G/5. Communication 1762**
Gas installations in multi-occupancy buildings (1 sides)

If the user copies these amendments onto A4 labels, the amendments can be cut out and applied to the appropriate places within the relevant technical publications i.e. the individual amendments are tailored to fit over the existing text.

Clause

6.4.2.4 Delete the clause entirely. Substitute:

Any PE pipe shall be completely sleeved with fire retardant glass reinforced plastic and secured with wall-mounted retaining clips or as instructed by the manufacturer or any proprietary systems.

Clause

11.2.2 Delete Note 1 entirely. Substitute:

Note 1: Insulating fittings complying with DIN 3389-1 are suitable for use inside buildings. Fittings complying solely with GIS/E17-2 are not suitable for use inside buildings. Fittings which are intended for use inside buildings need to be resistant to high temperatures in accordance with Annex A of BS EN 1775.

END OF AMENDMENTS